

## **TEST REPORT**

100 Clemson Research Blvd. Anderson, SC 29625 (864) 656-1094 Fax: (864) 656-1095 www.brickandtile.org



## Results of Tests on brick Conducted in accordance with C67/C67M - 23 Standard Test Methods for Sampling and Testing Brick and Structural Clay Tile

## 07/26/2023

Name: The Belden Brick Company

P. O. Box 430

Sugarcreek, OH 44681

Phone: 330-456-0031

Fax: 330-456-2694 Report Number: 11864-29523 Plant:

Sampled Date:

Sugarcreek 7/3/2023

Received Date: Fired Date:

7/3/2023

Fired Date: 7, Product Code:

7/3/2023

Lot Number:

Description: PLT 2, SHALE/FIRECLAY W/ADDITIVE REDUCED FIRE (PAVER, 2-3/4)

Absorption	1	2	3	4	5	Average	Test Date
24 Hour Cold Water (%)	0.6	0.7	0.7	0.7	0.7	0.7	7/12/2023
5 Hour Boiling Water (%)	1.0	1.0	1.1	1.6	1.1	1.1	
Saturation Coefficient	0.61	0.67	0.64	0.45	0.69	0.61	
Compressive Strength	1	2	3	4	5	Average	Test Date
psi	18,980	21,230	18,210	16,910	19,390	18,940	7/12/2023
Efflorescence	11	12	13	14	15		Test Date
Efflorescence Detection	Not Effloresced	Not Effloresced	Not Effloresced	Not Effloresced	Not Effloresced		7/17/2023
Breaking Load	1	2	3	4	5	Average	Test Date
lb/in	2,386	2,205	2,587	2,592	3,029	2,560	7/10/2023
Abrasion Resistance	1	2	3	4	5	Average	
	0.00	0.00	0.00	0.00	0.00	0.00	
E303 Surface Friction	1	2	3	4		Average	Test Date
BPN	61	58	63	59		60	7/25/2023

Surface Temperature (F): 70 Condition of Slider: Good
Test Surface Location: BML Test Surface Texture: Wirecut Paver

Type of Slider: Rubber

The brick represented by the test results shown here comply with the physical property requirements of the standards listed below:

ASTM C902 - 22 Standard Specification for Pedestrian and Light Traffic Paving Brick

Class: SX, MX, NX Type: I, II, III

Lab Reference: 11864.29523

ASTM C1272 - 22a Standard Specification for Heavy Vehicular Paving Brick

Type: F, R

Katherine Hill, Quality Manager

Page 1 of 1