

## **TEST REPORT**

100 Clemson Research Blvd. Anderson, SC 29625 (864) 656-1094 Fax: (864) 656-1095



## Results of Tests on brick Conducted in accordance with C67/C67M - 24 Standard Test Methods for Sampling and Testing Brick and Structural Clay Tile

## 09/16/2025

Plant:

Sampled Date:

Received Date:

Fired Date:

Sugarcreek

8/26/2025

8/26/2025

8/26/2025

Name: The Belden Brick Company

P. O. Box 430

Sugarcreek, OH 44681

Phone: 330-456-0031

Fax: 330-456-2694 Report Number: 14220-35283

Description: PLT 2, Shale/Fireclay No Additive (Paver, 2-1/4")

Absorption		1	2	3	4	5	Average	Test Date
24 Hour Cold Water (%)		0.8	0.7	0.9	0.7	0.7	0.8	9/4/2025
5 Hour Boiling Water (%)		1.0	0.8	1.0	8.0	8.0	0.9	
Saturation Coefficient		0.81	0.83	0.89	0.85	0.87	0.85	
Compressive Strength		1	2	3	4	5	Average	Test Date
	psi	26,350	26,530	27,400	29,320	28,310	27,580	9/9/2025
Efflorescence		11	12	13	14	15		Test Date
Efflorescence Detection		Not	Not	Not	Not	Not		9/5/2025
		Effloresced	Effloresced	Effloresced	Effloresced	Effloresced		
Breaking Load		1	2	3	4	5	Average	Test Date
	lb/in	1,348	1,220	1,223	1,389	1,471	1,330	9/8/2025
Abrasion Resistance		1	2	3	4	5	Average	
		0.00	0.00	0.00	0.00	0.00	0.00	

The brick represented by the test results shown here comply with the physical property requirements of the standards listed below:

ASTM C902 - 22 Standard Specification for Pedestrian and Light Traffic Paving Brick

Class: SX, MX, NX Type: I, II, III

ASTM C1272 - 22a Standard Specification for Heavy Vehicular Paving Brick

Type: R

Katherine Hill, Quality Manager

\*The temperature and humidity of the Bishop Materials Laboratory is constantly kept between 60-90F, and 30-70% RH. The sampling for these tests was done by the customer. These results are specific to the samples tested. A Simple Acceptance Decision Rule was applied when determining the conformity statement shown on this report. Reporting of test results follows the requirements of the appropriate ASTM Test Method. For information on the decision rules or measurement uncertainty, please contact Kathy Hill, BML Quality Manager. This test report shall not be reproduced except in full, without written approval of the laboratory.

Lab Reference: 14220.35283 Page 1 of 1